



Elaboration of an Optimized Source Term Reduction Program for a 58 Reactors Fleet

A. Rocher, M.-C. Benoit -Alet,
C. Datat-Blondeau, F. Renard
B. Voisin (EDF)

ISOE International Symposium
Brussel, 1-3 June 2016



CHANGER L'ÉNERGIE ENSEMBLE





Content

- 1. Systematic measurements of the Optimized Source Term Reduction Program**
- 2 . Results of the Source Term Indicators obtained at the begining of shutdowns.**
- 3. Remedies: curative action proposed**
- 4. Synthesis and conclusions**

Optimized Surveillance : RCS Index





- It has been implemented at EDF since the origin (Fessenheim 1 NPP), at the begining of shutdowns. This Index is historical : data are extremly rich for the EDF NNPs.
- It is obtained by the average of the dose rates measured on the primary loops. It represents the **contamination of the primary circuits**.
 - It helps in deciding to inject zinc for RP goals. Curative (high Co60 contamination level) and preventive (SG replacements, ...)



Optimized Surveillance : RB Index



- It has been implemented for all EDF reactors since 2011 at the beginning of the shutdown
- It is obtained by the average of the dose rates taken off the auxiliary circuits. It illustrates **the auxiliary circuits contamination** which is complementary to the RCS Index, itself limited to the primary circuit
- It helps in deciding which are the most polluted circuits to be decontaminated



Optimized Surveillance : CZT Gamma Spectrometry




- It has been deployed across the EDF Fleet since 2011 in complement to RB index on each shutdown, before and after oxygenation.
- It **characterises the contribution of the principal radioactive elements** of the primary and auxiliary Dose Rates.
 - It helps **to choose the appropriate chemical solution** for decontamination (+ to calculate efficiency).

CZT Optimized Program: 8 points

CZT optimized program			
P1a P1b	CVCS	Before purification system	Power operation After fuel download
P2a P2b	CVCS	After purification system	Power operation After fuel download
P3a P3b	CVCS	Exchanger	Power operation After fuel download
P4a P4b	RCS	Crossover leg	Hot shutdown Pool flooding beginning
P5a P5b	RCS	Hot leg	Hot shutdown Pool flooding beginning
P6a P6b	RCS	Cold leg	Hot shutdown Pool flooding beginning
P7a P7b	SIS	Valve	Hot shutdown Pool flooding beginning
P8a P8b	RHRS	Exchanger	Hot shutdown Pool flooding beginning

a : before oxygenation – b: after oxygenation.

Average of CZT - Results in 2011



CVCS (Co + Ag) – RCS (Co) – SIS (Co) – RHRS (Co + Ag)

Results of the Source Term Indicators (2014 outages)

The state of Source Term depends on the series.

Dose Rate Indices allow us to develop a Relevant Source Term Reduction Program.
Proposed remedy depends on circuit indices

Example: DR Index state used to develop the second series STR Program
(24 units : 4 loops)

1300 MW	2014 outages											Synthesis		
	Dose/hr.RCA	I _{avg}		I _{avz}	RB sub-index						Dom rate	Dose/hr.RCA	Evolution	
		RHRS	CVCS		NVDS	PZR	SG	RCS	FPCCS					
1														
2														
3														
4														
5														
6														
7														
8														
9														
10														
11														
12														
13														
14														
15														
16														
17														
18														
19														
20														
21														
22														
23														
24														

Index is red when > 25 % over the average

Ce document est la propriété d'EDF - Toute diffusion externe du présent document ou des informations qu'il contient est interdite

First series (34 units :3 loops)



The Source Term Reduction
Program is being defined
for the 2015-2021 period
43 Units are concerned



Results of the indicators and proposed curative action

Source Term Reduction Program : EDF Methodology

Circuit

Index

Remedy

Primary circuit

If the **I_{loop}** and/or **RCS** and/or **SG** indices are red, then the primary circuit is polluted

Optimization of the use of biological shielding – CADOR software

RHRS/CVCS circuits

If the **RHRS** and/or **CVCS** indices are red, then the RHRS and/or CVCS circuit(s) is (are) polluted

Chemical decontamination of the circuits using qualified process

Other auxiliary circuits

If the **NVDS** and/or **SIS** and/or **PZR** and/or **FPCCS** indices are red, then the units are polluted with hot spots

Hot spot elimination

CURATIVE ACTIONS (1/2)

■ 1- Chemical decontamination of Residual Heat Removal System (RHS) and/or Chemical Volumetric Control System (CVCS)

- Objective: implement a qualified chemical process on circuits to dramatically decrease the dose rates
- Process: oxydo-reduction processes / EMMAg or EMMAC-POA depending on the majority radionuclide (identified through CZT measurements) and materials in the circuit
- Average dose rate reduction factors of 2 to 3, estimated collective dose saving of many 100 person.mSv over 5 years.



■ 2 - Hot spot elimination actions

- Implement curative actions (flushing, replacement of valves, etc.) using existing good practices,
- Identify actions to limit the emergence of new hot spots.

CURATIVE ACTIONS (2/2)

■ 3 - Optimization of the use of biological shielding with the CADOR software

- Define the biological shielding plan with an optimization analysis depending on the work to be performed,
- Prepare organization, resources and means,
- Implement the identified biological shielding options, follow the efficiency and, if necessary, adapt the program,
- Provide feedback experience.




SYNTHESIS AND CONCLUSIONS



Implementation of the CADOR software

- 35 proposed implementations until 2021
- Feedback: 13 implementations since 2011. Average dose saving :
→ 26 person.mSv / standard outage and 71 person.mSv / 10-years outage



Chemical decontamination of RHRs and CVCS

- 27 selected units until 2021
- Feedback: 15 units cleaned up since 2004. Average dose saving :
→ 500 person.mSv estimated over the 5 outages following the decontamination



Hot spot elimination

- 28 priority units

▪ As a conclusion, 43 units may be treated to improve their source term: 75% of the units of the French Fleet. The distribution is the following :

- 15 units with only one proposed curative action,
- 14 units with 2 proposed curative actions,
- 14 units with 3 proposed curative actions: chemical decontamination , CADOR and, hot spot elimination.

THANK YOU