

# Hot Spot Experience at KKL





Kernkraftwerk Leibstadt

#### Situation found during operator walkdown:



# The situation found (schematic)





# What is it?: Nuclide identification

- History: Broken fuel pin in the past and 141 fuel pellets lost in spent fuel pool
- History: Control rod pins and rollers were removed in the fuel pool
- Fuel?
- Fuel cladding?
- Control Rod pin?
- Anything else?





# TG10S001 valve lower housing picture taken by endoscope





# The principle of spent fuel pool cleaning

- •Move the dirt from the spent fuel pool floor to the radwaste
- No submerged filter disposal





### **Transport path of Hot Spot**





#### Kernkraftwerk Leibstadt

#### Hot Spot #1 removal line up



Kernkraftwerk Leibstadt

# Mock - up





Kernkraftwerk Leibstadt

# Video: Hot-Spot vacuuming sequence TG10S001



#### Where did the Hot Spot go?





Commercial filter cartridge: clogging

Customized "star-filter": wider mesh, 800 mSv/h, disposal during Control Rod disposal campaign 2010





#### Situation after Hot Spot #1 removal

Hot - Spot am Ventil TG10S00 ZD04R105 Nach dem Entfernen des Hot - Spots Datum: 29.11.07 Visum: Stritt Oliver





Kernkraftwerk Leibstadt

# Hot Spot #2 inside drain line TG10S101

# Vacuum hose to filter



Clean water injection for backwash, including check-valve



# Video: Hot-Spot vacuuming sequence drain line TG10S101



#### Situation after Hot Spot #2 removal





## Situation before and after RFO24





TG10S001 5 mSv/h / 520 mSv/h Drain line of FPCCU pump protection mesh

620 mSv/h / 4'500 mSv/h

During RFO-24 fuel inspection fuel cladding needed to be brushed. Removed CRUD was pumped into FPCCU suction line. Good idea????



# Hot Spot #3



# Video: Hot-Spot vacuuming sequence TG10N100 pump protection mesh





#### Pump mesh before and after cleaning







Remaining Hot Particle #4 1200 mSv/h

Removed foreign material

# Installation of collar





collar prevents heavy particles from being washed into suction line



#### **Installation of additional Area Radiation Monitors**



•Continuous survey of dose rate situation and warning



# Remaining challenges: Hot Spot in filter housing TG10N001

- Option 1
- Remove TG10N001 internals including Hot Spot #4 and install blind part to prevent new Hot Spot build up.
- Install pump protection mesh elsewhere
- Residual heat removal from spent fuel pool during installation?



- Option 2
- Remove entire TG10N001 including Hot Spot #4 and install straight piece of piping
- Install pump protection mesh elsewhere
- Residual heat removal from spent fuel pool during installation?



# Conclusions

- If radioactivity is located in a safe place: Leave it there
- If radioactivity has to be moved: Follow the path to the final destination (= geological repository)
- Have your surveys/instruments in place
- Have your RP technicians ready to handle high dose rates
- Have your Foreign Materials Exclusion controls in place





# **Questions?**





Kernkraftwerk Leibstadt