


**Severe Accident Management:
Radiation Dose Control
Fukushima Daiichi and TMI-2 Nuclear Plants**

**ISOE Expert Group on Occupational Radiation
Protection in Severe Accident Management**


Nuclear Energy Institute

June 17, 2014

Roger P. Shaw, CHP, RSO
Principal, Shaw Partners LLC




RELATIVE BACKGROUND




- Former Director of Radiation Protection (RP),
Three Mile Island Nuclear Plant (post-accident)
- First RP Director of both TMI-1 *and* TMI-2
 - Radiation Field Operations, Radiological Engineering, Radiation Health, Radiation Instrumentation, Radiation Dosimetry
- Director of Occupational Safety & Health

RELATIVE BACKGROUND




- Directed the TMI-2 Radiological Controls Program from 1990 to the final shipment of damaged fuel to the DOE Idaho National Laboratory, and achievement of Post-Defueling Monitored Storage in 1993
- First radiation worker to enter the TMI-2 damaged containment (entry #66) and perform radiological surveys of the Reactor Coolant Pumps and pressurizer (1983) – 15-20 rem/hr (150-200 mSv/hr)

RELATIVE BACKGROUND



- Director of the Radiological Controls & Occupational Safety Program at the Oyster Creek Nuclear Plant (1993-1997)
- BWR-2 commercial operation 1969
~ ‘sister’ plant to Fukushima Daiichi Units 1-4



Three Mile Island Unit 2




- Pressurized Water Reactor (PWR)
- NSSS: Babcock & Wilcox (B&W) – 880 MWe
- Engineer: Burns & Roe and Gilbert
- Constructor: United Engineers and Constructors
- Initial Criticality: 28 March 1978
- Commercial Operation: 30 October 1978
- Accident: 28 March 1979
- Effective Full Power Days (EFPD) – <100 !



Three Mile Island Units 1 and 2

TMI-2 Control Room




No Replica Training Simulator Onsite - Unlike Today

TMI-2 Accident Chronology

- 28 March 1979 – 33 years ago
- 16 March 1979 “China Syndrome” movie released and in theaters around TMI
- 23 July 1980 – 1st Reactor Building Entry
- July 1984 – Reactor Vessel Head removed
- October 1985 – Defueling began
- July 1986 – 1st off-site shipment of reactor core debris
- January 1990 – Defueling completed
- 28 December 1993 - PDMS Approved by NRC
- Spent Fuel in Dry Storage at Idaho National Lab

TMI-2 Reactor Vessel




Major Considerations for TMI-2 & Fukushima Daiichi Accidents

- Obvious – PWR vs. BWR
- Single Unit vs. Multiple Units
- Primary Containment Remained Intact
- Reactor Vessel Not breached
- Effluent Releases via Auxiliary Bldg. (except Kr-85)
- Spent Fuel Pool - not damaged and played no role
- No real site damage (except core damage)
- Hydrogen ‘burn’ but no hydrogen explosion
- No Station Blackout or offsite power loss
- No extensive detectable offsite contamination
- No required evacuation of general public



No Damage to Turbine Building (TMI-1 shown here)



LEGEND

- | | | |
|--|---------------------------|-------------------------------------|
| | - PUMP | BWST - BORATED WATER STORAGE TANK |
| | - RADIATION MONITOR | R.C. - REACTOR COOLANT |
| | - RELIEF VALVE | R.B. - REACTOR BUILDING |
| | - MOTOR OPERATED VALVE | F.W. - FEEDWATER |
| | - AIR OPERATED VALVE | AOV - AIR OPERATED VALVE |
| | - CHECK VALVE | OTSG - ONCE THROUGH STEAM GENERATOR |
| | - SYSTEMS ON AUTO STANDBY | |

GPU Nuclear

TMI-1 SYSTEMS

PREPARED BY GPU NUCLEAR CORPORATION
COMMUNICATIONS DIVISION

Exemplary Leadership

- Strong Safety Culture – Before NRC Required
- Strong Senior Leadership
- President/Vice-President worked directly for Admiral Rickover – Father of U.S. Nuclear Navy
- Several Nuclear Navy Admirals served as Directors
- For extended time – >20 NRC Inspectors onsite
- State of Pennsylvania oversight
- Improved public outreach following poor start
 - Local Physicians trained after some abortions inappropriately recommended
 - Whole Body Counts offered to general public



Exceptional Radiological Controls

- Strong work management
- Exceptionally qualified staff hired
- High priority from Senior Management
 - Radiation Protection Policy
 - Radiation Protection Plan
 - Radiation Procedures – verbatim compliance
 - ALARA Committee
 - Mockups
 - Advanced Radiation Worker Training
 - Stop Work Authority at Radiation Technician Level
 - Pre- and post-job briefings
- Committed to Excellence

Innovation with Radiological Controls


- Digital Reading Dosimeters (DRD)
- Breathing Zone Air (lapel) Samplers
- Powered Air Purifying Respirators (PAPR)
- Whole Body Contamination Monitors
- Ice vests and Vortex suits for worker cooling
- Hydration for high heat area entries
- Completely assisted PPE donning and removal for all Reactor Build. entries – fully ready rescue crews
- Multiple dosimeter packs where needed (up to ~10 dosimeters due to radiation stratification)
- Command & Control Room for RB entries

TMI-2 PDMS Requirements

- **<1% Failed Fuel remaining**
- **No real potential for liquid or airborne effluents**
Reactor Building – “Breather” system with passive ventilation system – maintained at atmospheric pressure
Liquids sampled for any groundwater intrusion/effluent
- **No fire damage potential**
- **All accident generated water (AGW) processed**
- **Long-term radiological surveillance program in place**
- **Decommissioning funds in escrow**
- **Unit-2 to be decommissioned when Unit-1 done**
- **Others**

Recovery and Defueling Issues

- Major engineering undertaking
- Extensive radiological controls challenge
- Performing tasks not performed before
- RV Core Bore Drilling
- Plasma Arc Torch cutting of fuel and reactor internals
- Use of long-handled tools – hydraulics and hand
- Special design equipment
- Highly specialized contractors needed
- Major use of robotics...




T.M.I. Rover

Designed for Use at Three Mile Island Nuclear Power Plant, Pittsburgh, Pennsylvania – Standard's six wheel, 570 lb. undercarriage was developed for use in contaminated areas for initial surveillance as part of the radioactive waste cleanup program for the power plant. The undercarriage measures 50" long x 29" wide x 19" high and operates electrically by remote control.



Robotics Photos from Video



TMI "Workhorse" Hydrolasing Robotics
50k psi Water



Standard Fukushima Robotics



More Advanced Fukushima Robotics

D&D Categories (U.S.)

DECON (Decontamination)

*SAFSTOR (Safe Storage) – TMI-2 PDMS –
Essentially meets SAFSTOR requirements*

ENTOMB

Q: Should *Key Robotics* be part of Regional or Country Emergency Equipment Centers?

- Strategic Alliance for FLEX Emergency Response (SAFER) in the U.S. model or others?
- Many lessons learned from 9/11 FDNY - compatibility
- Radiation and Video Monitoring as a minimum?
- Utilize local Bomb Squad robotics and quickly adapt?
Non-nuclear experience issues?
- Utilize most local known NPP robotics via MOU?

Dose Estimates for Cleanup

TOTAL CUMULATIVE RADIATION WORKER DOSE

MINIMUM – 2000 person-rem (20,000 person - mSv)*

MAXIMUM – 8000 person-rem (80,000 person - mSv)*

OTHER ESTIMATES – AS HIGH AS >20,000 person-rem
(>200,000 person - mSv)

*NUREG-0683 – *Estimated (1981)*

Major PDMS Activities

TMI-2 WORKER DOSE FOR MAJOR ACTIVITIES

1986 - 1989

<u>ACTIVITY</u>	<u>PERSON-REM</u>
Defueling Operations (reactor vessel only)	698
Defueling Support (tool repairs, water cleanup)	1058
Reactor Building Miscellaneous (robotics, crane ops, radwaste, etc.)	765
Decontamination (outside the reactor building)	424
Routine Operations (ops, chemistry, rad con outside reactor building)	277
Ex-Vessel Defueling (pressurizer, OTSG, etc.)	216
TOTAL	3438

Worker Cumulative Dose

Estimated TOTAL

1979-1993 to reach PDMS

~6,600 person-rem (66,000 mSv)

- ~62,500 person-mSv*
- ~3,500 person-mSv**

*GPU Nuclear TMI-2 Annual Dose Report

**USNRC NUREG-0713

NOTE: Total includes some TLD and some Self-Reading Dosimeter data

Worker Cumulative Dose through 1989

TABLE 5

LIFETIME OCCUPATIONAL RADIATION EXPOSURE FOR TMI-2 WORKERS*

<u>LIFETIME DOSE RANGE (millirem)</u>	<u>PERCENTAGE OF TMI-2 WORKERS</u>
Less than 1000	35
1000-3000	11
3000-5000	12
5000-10,000	21
10,000-20,000	17
Greater than 20,000	4
TOTAL	100

* Lifetime exposures include occupational doses received at TMI-2 and all other facilities where persons have worked.

TMI-2 Worker Overexposures

- Twelve (12) *instances* during initial accident response
- WB doses from TMI-1 **post accident RCS sample**
 - 4.1 rem (41 mSv) by 2 workers
 - 3.9 (39 mSv) rem by 1 worker
- One (1) additional in 1986 – handled a fuel chunk
- **NO** acute injuries
- Each individual received a medical evaluation
- Internal doses generally low – **NO** overexposures
- **NO** overexposures due to Discrete Radioactive Particles (DRPs or “hot particles”)
- Total number of individuals with overexposures = **13**

Q: RCS Samples to Determine Failed Fuel – Are they worth taking?


- **Caused 3 WB doses in excess of regulatory limits**
- **Lost chemistry & radiological count room**
- **No way to count RCS sample onsite – dose rates**
- **Shipped offsite on C-130 Air Force Plane**
- **No proper shipping papers – NRC ‘sanctioned’**
- **Better alternative method? What precision needed?**




**PPE Issues Played a Major Role
Care needed with Sr-90/Y-90 and alpha !!**

Reactor Building Entrance Airlock





Remote Defueling Operation Over Reactor Vessel



Remote Shielded Rotating Work Platform



Personnel Protective Equipment for Platform Work



Training to visually identify Fuel/Corium



Reactor Vessel Turbidity Problems



Reactor Vessel Turbidity Problems

PREPARING FOR MONITORED STORAGE



By January 1990, defuelers completed removing approximately 99 percent of the core debris from the reactor vessel — thereby eliminating any possibility of a chain reaction occurring in the plant. The work was slow; at times workers removed debris piece-by-piece. However, removing the damaged fuel was necessary to protect the safety of the workers and the public.


Monitored storage will mark the successful completion of the Cleanup Program goal by removing any radiological hazard to the public, TMI workers and the environment.

During monitored storage, the reactor building is to be locked, but accessible for monitoring by a full-time staff.

Above: Landmark photograph shows empty bottom of the Unit 2 reactor vessel. The vessel bottom is at the bottom right of the photograph, which was taken from videotape.

Top Right: International attention was once again focused on TMI-2 when samples were removed from the reactor vessel. The samples were sent around the world for analysis to determine what effect the accident had on the vessel. Here a straight-edged tool is used to determine that the surface of the sample is flat.


Bottom Right: The empty reactor vessel.




Spent Fuel Pool Bay for both Units

TMI-1: bottom of
photo with *normal*
configuration


TMI-2: top of photo
with Submerged
Demin System (SDS)






TMI-2 Spent Fuel Pool SDS

USDOT Approved Rail Shipping - Spent Fuel






United States

Department of Energy

Science, Technology and Energy for our Future

Fukushima Worker Doses




Cumulative dose of all the workers worked at Fukushima Daiichi site
(Accident March 11-December 2013)????

Dose (mSv)	The number of TEPCO employees	The number of Subcontractor employees	Total
>250	6	0	6
200-250	1	2	3
150-200	24	2	26
100-150	118	20	138
75-100	255	112	367
50-75	323	850	1173
20-50	607	4197	4804
10-20	544	3875	4419
5-10	431	3687	4118
1-5	707	6835	7542
1>	1070	7717	8787
Total	4086	27297	31383
Max(mSv)	678.8	238.42	678.8
Average(mSv)	23.6	10.97	12.61

SOURCE: Health, Labour and Welfare Ministry of Japan

Fukushima Worker Doses



Cumulative dose of all the workers worked at Fukushima Daiichi site
(2013.4-2013.12)

Dose (mSv)	The number of TEPCO employees	The number of Subcontractor employees	Total
>100	0	0	0
75-100	0	0	0
50-75	0	0	0
20-50	19	377	396
10-20	54	1370	1424
5-10	157	1592	1749
1-5	643	3284	3927
1>	735	4104	4839
Total	1608	10727	12335
Max(mSv)	34.7	39.7	39.7
Average(mSv)	2.61	4.69	4.42

SOURCE: Health, Labour and Welfare Ministry of Japan

Some Key Points Given to 5 Japan Parliament Members in June 16 Meeting

- Simple conclusion could be that Daiichi was 3-4 times worse than TMI-2
- Not the case – may present ~8-12 times the magnitude of a challenge
- TMI-2 had no extensive plant damage
- No penetration through reactor vessel
- The task is enormous and will require incredible effort and cooperation
- National and International level of effort with the best minds and talent necessary

Some Key Points Given to 5 Japan Parliament Members in June 16 Meeting

- Major Hot Spots exist (throughout plants)
- Fuel Fragments (highly radioactive) - >10,000 mSv/hr
- Discrete Radioactive Particles - fuel, fission and activation products)
- These DRP's are invisible to the eye - can act like 'fleas' due to electrostatic charge
- Plutonium (strong public reaction expected)
- Tritium – radioactive 'water' – cannot remove like particles (problematic effluent)

Some Key Points Given to 5 Japan Parliament Members in June 16 Meeting

- Build airplane type hanger structure to contain each Daiichi units
- May need to adjust regulations for radiation worker Dose Limits such as 100 mSv in 5 years
- To clean to 95%, may require 50-100k trained radiation workers
- Radioactive waster processing and volume reduction is critical
- NO nuclear plant in the world has seen a 15 meter tsunami and 9.0 earthquake

Temporary and Permanent Protective Covers for Unit 1





Kyle Drubek On the outskirts of Fukushima city, a farmer spreads zeolite -- intended to absorb and concentrate radioactive cesium -- across his rice field in preparation for planting.

Dedicated to the memory of Mr. Wataru Mizumachi

