OECD Nuclear Energy Agency International Atomic Energy Agency



INFORMATION SYSTEM ON OCCUPATIONAL EXPOSURE

## **General Distribution**

**June 2013** 

# **ISOE INFORMATION SHEET**

North American Technical Center Information System on Occupational Exposure

3-YEAR ROLLING AVERAGE ANNUAL DOSE COMPARISONS Canada Reactors (CANDU) 2010-2012 Occupational Dose Benchmarking Charts

#### **NATC ISOE Information Sheet No. 2013-15**

NATC ISOE Information Sheet No. 2013-15 presents the Canadian reactor annual occupational exposure results for multiple years (2002-2012). The 3-Year Rolling Average Occupational Dose Comparisons provide a means to evaluate site occupational dose performance over multiple years. The data shows the higher outage doses during years of extensive maintenance/refurbishment work at Bruce A 1,2 & Pt. Lepreau performed to achieve future dose reduction due to installation of new plant components.

For this report, annual site doses were used for 2010, 2011 and 2012. Annual site doses were divided by the number of operating units per site. The 3-Year

Rolling Average results for this period are provided in the following table.

Site Name	Three Year Rolling Average Person-Rem (Person-mSv)				
Bruce A	260 (2600)				
Pickering	452 (4520)				
Darlington	59 (590)				
Point Lepreau	143 (1430)				
Bruce B	101 (1010)				
Gentilly	56 (560)				

Table 1: Canadian Three-Year Rolling Average, 2010-2012.

# Table 1: CANADIAN REACTORS: COLLECTIVE DOSE PER UNIT THREE YEAR ROLLING AVERAGE

## 2010 - 2012 Actual Values

			Collective Radiation Exposure Per Site (Person-Rem)											Three Year Rolling Average
SITE NAME	No. of Units	СТУ	2002	2003	2004	2005	2006	2007	2008	2009	2010	2011	2012	Per Unit
Darlington	4	Ca	210	284.4	262.54	283.99	320	410	173.6	313.54	368.1	166.6	179.2	59
Pickering	6*	Ca	509.2	434.68	807.6	1132	766.4	587.2	473.18	774	1678.9	608.9	841.9	452
Bruce A	4	Ca	243.49	218	147.56	234.17	335.53	468.42	744.4	733.9	766.5	1031.9	1325.58	260
Bruce B	4	Ca	491	424	270.28	634.11	380.41	421.16	665.08	510.81	361.3	710.2	140.44	101
Point Lepreau	1	Ca	135.35	114.6	91.9	157.69	90.08	66.43	599.75	408.22	137.5	195.3	94.7	143
Gentilly	1	Ca	151.86	287.27	30.52	149.86	138	53.1	115.2	67.66	74.6	70.2	22.9	56
20*		1740.90	1762.95	1610.39	2591.81	2030.42	2006.31	2771.21	2808.12	3386.9	2783.1	2604.72		
Total of Canadian Units Included		22	22	22	22	22	22	22	22	22	20	20		
Annual CANDU Average		79.13	80.13	73.20	117.81	92.29	91.20	125.96	127.64	153.95	139.16	130.24		

<sup>\*</sup>Pickering 2 and 3 went into long-term safe storage in 2011.